

Table 2 - Consequence Analysis: Raffinate System with Reboiler

<u>CONSEQUENCE SUMMARY</u>																																				
RAST Version 2		Date: 12/1/2019																																		
Loss Event for: Distillation; Rafinate Splitter Containing Overfill Release Pentane (n-):																																				
<p>Explosion Summary:</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;">VCE or Building Explosion Energy, kcal</td> <td style="width: 20%; text-align: center;">2.4E+07</td> <td style="width: 20%;">Probability of Ignition (POI)</td> </tr> <tr> <td>VCE or Building Explosion Distance to 1 psi Overpressure, m</td> <td style="text-align: center;">288.5</td> <td rowspan="2" style="text-align: center; vertical-align: middle;"><i>Potential Explosion Impact to Occupied Building</i></td> </tr> <tr> <td>Maximum Distance to LFL Concentration, m</td> <td style="text-align: center;">202.1</td> </tr> <tr> <td>Blast Overpressure at Center of Occupied Building 1, psi</td> <td style="text-align: center;">3.2</td> <td rowspan="2" style="text-align: center; vertical-align: middle;">Probability of Explosion (POX)</td> </tr> <tr> <td>Blast Overpressure at Center of Occupied Building 2, psi</td> <td style="text-align: center;">0.0</td> </tr> <tr> <td>Distance to Severe Thermal Radiation Impact, m</td> <td></td> <td></td> </tr> <tr> <td>Rupture Explosion Energy, kcal</td> <td></td> <td></td> </tr> <tr> <td>Distance to Direct Blast Impact (10 psi), m</td> <td></td> <td></td> </tr> <tr> <td>Maximum Fragment Range, m</td> <td></td> <td></td> </tr> <tr> <td>Rupture Distance to 1 psi Overpressure, m</td> <td></td> <td></td> </tr> <tr> <td>Rupture Overpressure at Center of Occupied Building 1, psi</td> <td style="text-align: center;">0.0</td> <td></td> </tr> <tr> <td>Rupture Overpressure at Center of Occupied Building 2, psi</td> <td style="text-align: center;">0.0</td> <td></td> </tr> </table>			VCE or Building Explosion Energy, kcal	2.4E+07	Probability of Ignition (POI)	VCE or Building Explosion Distance to 1 psi Overpressure, m	288.5	<i>Potential Explosion Impact to Occupied Building</i>	Maximum Distance to LFL Concentration, m	202.1	Blast Overpressure at Center of Occupied Building 1, psi	3.2	Probability of Explosion (POX)	Blast Overpressure at Center of Occupied Building 2, psi	0.0	Distance to Severe Thermal Radiation Impact, m			Rupture Explosion Energy, kcal			Distance to Direct Blast Impact (10 psi), m			Maximum Fragment Range, m			Rupture Distance to 1 psi Overpressure, m			Rupture Overpressure at Center of Occupied Building 1, psi	0.0		Rupture Overpressure at Center of Occupied Building 2, psi	0.0	
VCE or Building Explosion Energy, kcal	2.4E+07	Probability of Ignition (POI)																																		
VCE or Building Explosion Distance to 1 psi Overpressure, m	288.5	<i>Potential Explosion Impact to Occupied Building</i>																																		
Maximum Distance to LFL Concentration, m	202.1																																			
Blast Overpressure at Center of Occupied Building 1, psi	3.2	Probability of Explosion (POX)																																		
Blast Overpressure at Center of Occupied Building 2, psi	0.0																																			
Distance to Severe Thermal Radiation Impact, m																																				
Rupture Explosion Energy, kcal																																				
Distance to Direct Blast Impact (10 psi), m																																				
Maximum Fragment Range, m																																				
Rupture Distance to 1 psi Overpressure, m																																				
Rupture Overpressure at Center of Occupied Building 1, psi	0.0																																			
Rupture Overpressure at Center of Occupied Building 2, psi	0.0																																			
<p>Incident Outcome and Consequence Summary:</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%;">Impact Assessment with Personnel routinely in the immediate area</th> <th style="width: 10%;">Exceeds Threshold Criteria</th> <th style="width: 40%;">LOPA Tolerable Frequency Factors Based Estimated Number of People Impacted</th> </tr> </thead> <tbody> <tr> <td>Offsite Toxic Impact based on Toxic Integration Method and 1000 m to Fence Line</td> <td style="text-align: center;">Yes</td> <td style="text-align: center;">NA</td> </tr> <tr> <td>Onsite Toxic Impact based on Distance to LC-50 Concentration of 43 m <i>Outdoor Toxic Exposure Duration 600 sec</i></td> <td></td> <td style="text-align: center;">NA</td> </tr> <tr> <td>Onsite Flash Fire Impact based on Distance to 0.5 LFL Concentration of 286 m</td> <td></td> <td style="text-align: center;">5</td> </tr> <tr> <td>Chemical Exposure based on Dermal or Thermal Hazards and Spray Distance of 0 m</td> <td></td> <td style="text-align: center;">NA</td> </tr> <tr> <td>Onsite Direct Blast Impact based on Distance to 10 psi of 0 m</td> <td></td> <td></td> </tr> <tr> <td>Onsite Thermal Radiation Impact based on Distance from Fireball of 0 m</td> <td></td> <td></td> </tr> <tr> <td>Occupied Building Toxic Impact <i>Number of Potential Serious Injuries</i> <i>Number of Potential Serious Injuries</i></td> <td></td> <td style="text-align: center;">NA</td> </tr> <tr> <td>Occupied Building Impact from Vapor Cloud Explosion <i>Number of Potential Serious Impacts for Building 1: 18 people</i> <i>Number of Potential Serious Impacts for Building 2: 0 people</i></td> <td style="text-align: center;">Yes</td> <td style="text-align: center;">6</td> </tr> </tbody> </table>			Impact Assessment with Personnel routinely in the immediate area	Exceeds Threshold Criteria	LOPA Tolerable Frequency Factors Based Estimated Number of People Impacted	Offsite Toxic Impact based on Toxic Integration Method and 1000 m to Fence Line	Yes	NA	Onsite Toxic Impact based on Distance to LC-50 Concentration of 43 m <i>Outdoor Toxic Exposure Duration 600 sec</i>		NA	Onsite Flash Fire Impact based on Distance to 0.5 LFL Concentration of 286 m		5	Chemical Exposure based on Dermal or Thermal Hazards and Spray Distance of 0 m		NA	Onsite Direct Blast Impact based on Distance to 10 psi of 0 m			Onsite Thermal Radiation Impact based on Distance from Fireball of 0 m			Occupied Building Toxic Impact <i>Number of Potential Serious Injuries</i> <i>Number of Potential Serious Injuries</i>		NA	Occupied Building Impact from Vapor Cloud Explosion <i>Number of Potential Serious Impacts for Building 1: 18 people</i> <i>Number of Potential Serious Impacts for Building 2: 0 people</i>	Yes	6							
Impact Assessment with Personnel routinely in the immediate area	Exceeds Threshold Criteria	LOPA Tolerable Frequency Factors Based Estimated Number of People Impacted																																		
Offsite Toxic Impact based on Toxic Integration Method and 1000 m to Fence Line	Yes	NA																																		
Onsite Toxic Impact based on Distance to LC-50 Concentration of 43 m <i>Outdoor Toxic Exposure Duration 600 sec</i>		NA																																		
Onsite Flash Fire Impact based on Distance to 0.5 LFL Concentration of 286 m		5																																		
Chemical Exposure based on Dermal or Thermal Hazards and Spray Distance of 0 m		NA																																		
Onsite Direct Blast Impact based on Distance to 10 psi of 0 m																																				
Onsite Thermal Radiation Impact based on Distance from Fireball of 0 m																																				
Occupied Building Toxic Impact <i>Number of Potential Serious Injuries</i> <i>Number of Potential Serious Injuries</i>		NA																																		
Occupied Building Impact from Vapor Cloud Explosion <i>Number of Potential Serious Impacts for Building 1: 18 people</i> <i>Number of Potential Serious Impacts for Building 2: 0 people</i>	Yes	6																																		

**Step 4
(Worst Case Outcome)**