

The Relationship Between Drinking Water Quality in a Single Family Home and the Service Line

Maryam Salehi, Tolu Odimayomi, Kyungyeon Ra, Christian Ley, Ryan Julien, A. Pouyan Nejadhashemi

J. Sebastian Hernandez-Suarez, Jade Mitchell, Amisha D. Shah, Andrew Whelton

Department of Civil Engineering

University of Memphis

*Lyles School of Civil Engineering, Division of Ecological and
Environmental Engineering & School of Mechanical Engineering*


Purdue University


*Department of Biosystems and Agricultural Engineering &
Department of Plant, Soil and Microbial Sciences*

Michigan State University




THE UNIVERSITY OF
MEMPHIS






Changes to contaminant levels can be attributed to plumbing materials, temperature, pH, and water stagnation.



The time of day and season can influence water quality characteristics.



The Link between Fixture Water Use and Drinking Water Quality at a Net Zero Energy Residential Building

Chemosphere 195 (2018) 80–89



Contents lists available at ScienceDirect

Chemosphere

journal homepage: www.elsevier.com/locate/chemosphere



Case study: Fixture water use and drinking water quality in a new residential green building



Maryam Salehi ^a, Mohammad Abouali ^b, Mian Wang ^a, Zhi Zhou ^{a, c},
Amir Pouyan Nejadhashemi ^{a, d}, Jade Mitchell ^b, Stephen Caskey ^e, Andrew J. Whelton ^{a, c, *}

^a Lyles School of Civil Engineering, Purdue University, West Lafayette, IN, USA

^b Department of Biosystems and Agricultural Engineering, Michigan State University, East Lansing, MI, USA

^c Division of Ecological and Environmental Engineering, Purdue University, West Lafayette, IN, USA

^d Department of Plant, Soil and Microbial Sciences, Michigan State University, East Lansing, MI, USA

^e School of Mechanical Engineering, Purdue University, West Lafayette, IN, USA



THE UNIVERSITY OF
MEMPHIS®

Research Goal

Investigate temporal & spatial variations of tap water chemical quality at a net-zero energy building.

Examine water chemical quality fluctuations at the point of entry the building.

Objectives

Elucidate spatial and temporal variations of water quality inside the building.

Explore the reasons caused spatial and temporal variations of tap water quality.



THE UNIVERSITY OF
MEMPHIS


Online Flow and Temperature
Monitoring at All Fixtures



Online Water Quality
Monitoring at Service Line

ReNEWW House

Retrofit Net Zero: Energy. Water. Waste.



Low Water Use and In-Building Stagnation Varied by Season

Season (Occupancy/Day) and Water Use Characteristics			Fixture Locations						
			Service Line	1 st Flr Cold	2 nd Flr Cold	2 nd Flr Shower	Water Heater	1 st Flr Hot	2 nd Flr Hot
Fall (2.8) ¹	Total Volume, m ³		25.5	0.9	0.4	8.1	8.7	1.0	3.5
	Stagnation, hr	\bar{x}	0.3	1.0	2.2	2.3	0.5	1.2	1.1
		90 th tile	0.0	2.2	7.3	3.6	0.9	2.0	2.5
		Max	37.5	153.0	102.7	120.0	152.0	153.0	150.2
Winter (2.2) ¹	Total Volume, m ³		23.6	0.8	0.4	7.3	8.3	1.0	4.8
	Stagnation, hr	\bar{x}	0.3	1.1	3.2	3.4	0.4	1.0	1.1
		90 th tile	0.6	2.2	9.7	9.3	0.8	2.0	2.2
		Max	16.0	99.4	69.9	72.3	50.7	72.9	72.6
Spring (1.5) ¹	Total Volume, m ³		19.7	0.5	0.2	4.7	5.9	0.8	2.5
	Stagnation, hr	\bar{x}	0.5	2.2	5.3	4.5	0.7	1.6	1.7
		90 th tile	1.0	4.1	11.6	13.8	1.1	2.8	3.0
		Max	25.8	114.1	123.1	60.7	68.9	116.2	67.0
Summer (2.7) ¹	Total Volume, m ³		23.8	0.9	0.2	3.7	4.3	0.7	1.0
	Stagnation, hr	\bar{x}	0.1	1.3	3.9	5.7	0.7	1.6	1.7
		90 th tile	0.1	2.2	7.6	15.6	1.2	2.6	3.0
		Max	47.0	118.6	145.1	79.0	95.4	142.5	65.8

¹ Average outdoor temperature: 5.4 °C (Fall), -0.7 °C (Winter), 15.6 °C (Spring), 22.6 °C (Summer), calculated using data reported at *Weather Underground*. Average daily occupancy is reported as persons/day. \bar{x} = mean.


Water Quality Significantly Varied at the Service Line



Parameter		Public Water System	Fall	Winter	Spring	Summer
General	Temp, °C	nr	21.6	→ 14.6	21.1	22.9
	pH	7.6	7.7	7.7	7.7	7.5
	Total Cl ₂ , mg/L	1.2	0.4	→ 0.9	0.6	0.4
	Free Cl ₂ , mg/L	nr	0.3	-	0.4	0.4
Organics	TOC, mg/L	nr	0.5	0.5	0.6	0.5
	DOC, mg/L	nr	0.5	0.5	0.5	0.5
	TTHM, µg/L	19.2 ³	<1.4	<1.4	→ 2.5	<1.4
Heavy Metals	Pb, µg/L	nd ⁶	<1.1	<1.1	<1.1	<1.1
	Zn, µg/L	nr	14.3	14.1	→ 26.6	10.4
	Cu, µg/L	565 ³	81.2	75.5	72.6	→ 32.2
	Fe, µg/L	20 ¹	19.1	16.7	6.2	6.7
	Mn, µg/L	20 ¹	3.1	2.9	1.8	2.0
Nitrogen	NH ₃ -N, mg/L	nr	→ 0.4	<0.01	<0.01	0.1
	NO ₃ -N, mg/L	0.2	0.5	0.8	0.6	0.1



Online Service Line Monitoring Confirmed Drinking Water Quality Fluctuations

Turbidity peaks match peak flow rates, and may indicate hydraulic impacted biofilm and inorganic scale suspension.




Online water quality monitoring

Water pH and water temperature increased in the building

- Water pH at the service line (7.2-7.8) *Increased*  through the building (7.2-9.4).
- The greatest water pH values were found at the 1st floor cold (7.5-9.4) and 2nd floor hot (7.7-9.0) water fixtures.
- About 11% of all faucet pH values exceeded the SMCL of 8.5.
- Water temperature at the service line (19.6 °C) *Increased*  through the building (23 °C).

TOC levels were often greatest in the cold water plumbing.

A positive correlation was found between organic carbon concentration with water pH.



Bench Scale Study: pH and temperature influenced organic release





Water pH and Exposure Time		Total Organic Carbon (TOC) Concentration (mg/L)			
		PEX-a Pipe		PEX-b Pipe	
		23°C	50°C	23°C	50°C
pH 7	Day 3	13.09	41.29	16.66	58.92
	Day 15	3.33	5.71	0.89	12.88
	Day 30	5.07	3.44	1.08	10.77
	Sum	21.49	50.44	18.63	82.57
pH 10	Day 3	-	77.69	-	39.95
	Day 15	-	5.64	-	7.26
	Day 30	-	1.55	-	5.25
	Sum	-	84.88	-	52.46

Disinfectant residual levels decreased through the building while TTHM concentrations increased.

For more than 85% of the sampling trips, disinfectant residual was not detected at the water heater, the 2nd floor cold, and 2nd floor shower fixture.

A significant negative correlation between Temp & disinfectant residual at all fixtures except the water heater and 2nd Flr shower




The water softener treated all water from the service line

Hardness	385 mg/L as CaCO_3	19 mg/L as CaCO_3
Ca^{2+}	99 mg/L	2 mg/L
Mg^{2+}	34 mg/L	4 mg/L
Na^+	23 mg/L	178 mg/L



At Service Line

In Building




Zn, Pb & Cu leached from the building plumbing while Fe & Mn deposited onto the plumbing.


New PEX 1 Year Old PEX




Potential Seasonal Nitrification



Study results suggest seasonal nitrification occurred in the hot water plumbing.




NO₂-N was not detected at the service line or cold water samples, but was found during short Spring and Summer periods (0.02-0.05 mg/L) in hot water plumbing.



Significantly lower NO₃-N levels were found in afternoon water samples compared to the morning or mid-day.




The Need for Technology & Considerations for Future Building Water Quality Studies




The sensor technology is needed to better capture water quality variability at the service line and within buildings.


Future studies should consider:



The impact of new and aged (or established) plumbing on water quality.



The role hydraulic factors contribute to biofilm or scale suspension and thereby delivery to plumbing fixtures.



Contaminant deposition and release within plumbing.